

EXTERNAL FIRE PROPERTIES OF KATEPAL BITUMEN SHINGLES

We hereby certify that the type approved (acc. Finnish ministry of environment YM25/6221/2003) bitumen products made by Katepal Oy, including bitumen shingles, are tested according to standard ENV 1187 (Test 2), meet the European fire requirements class B_{roof}(t2) as described in the classification standard prEN 13501-5 for external fire.

Lempäälä 2005-03-10

KATEPAL OY
Timo Rantanen
R&D Manager

